

# submittal

Job \_\_\_\_\_  
 Location \_\_\_\_\_  
 Submitted to \_\_\_\_\_  
 Submittal Prepared by \_\_\_\_\_  
 Approve Date \_\_\_\_\_  
 Date \_\_\_\_\_

## Model 50 EAX With Box Assembly

UL Classified - For use in UL 263 wood truss floor/ceiling assemblies rated 1hour

Approved for use in UL L-587\*, L-562, L-528, P-556\*, and P-580 designs

\* AT1 Exclusive Listings

Incorporates UL 555C evaluated ceiling damper


22 Ga CRD frame and blades

Factory installed 26 Ga box  
Collar by others (field cut and installed)

Standard fusible link - 165° F (optional 212° F)

Ceramic Thermal Blanket provided on units with CRD blade areas of greater than 84 sq. in.

Available in single-section sizes from 4" x 8" to 14" x 14"



This product meets the requirements for ceiling dampers established by:

**UL Standards 263 & 555C**  
**NFPA Standard 90A**  
**ICC Building Codes**

Qty.	Damper Size		Box Height	Fusible Link Temp (165°F) std.	Flange Configuration		
	W	H			F	F1	N

## Part Number Format

5 0 E A X 0 6 1 0 G 7 F

**MODEL**

50 SERIES - CRD, RECTANGULAR, 3 HR

**METHOD OF LINK ATTACHMENT**

EAX - (CRD) EASY ACCESS LINK, IN METAL BOX

DAMPER  
WIDTH

DAMPER  
HEIGHT

BOX HEIGHT

7 - 17"  
4 - 14"  
2 - 12"

**MATERIAL & LINK TEMP.**

G - GALVANIZED, W/165° LINK  
H - GALVANIZED, W/212° LINK

F - 5/8" FLANGE  
F1 - 1" FLANGE

submittal



**AireTechnologies, Inc**  
a DMI company

AireTechnologies, Inc.  
1502 Industrial Drive  
E. Monongahela, PA 15063

phone: 866.421.AIRE  
fax 724.310.1262

www.airetechnologies.com